

# JAMESTOWN ELEMENTARY SCHOOL TESTING OF LEAD IN WATER (22 July 2016)

Area/Room	Draw1 PPB	Flush2 PPB	Area/Room	Draw1 PPB	Flush2 PPB	Area/Room	Draw1 PPB	Flush2 PPB	Area/Room	Draw1 PPB	Flush2 PPB
811	1.1	<1	506	2.5	2.1	702	ND	ND	200	1.1	<1
804 Kitchen	1.6	<1	506A	1.7	<1	704	2	2	110	3.3	<1
800 Cafeteria Fountain	41.8	37.2	508	<1	<1	706 Sink 1	<1	<1	at 110 Water Fountain	1.1	<1
at 416 Hall Fountain R	<1	<1	512	3.8	<1	706 Sink 2	<1	<1	111	60.6	2.4
at 416 Hall Fountain L	<1	<1	at 522 Hall Fountain L	<1	<1	701	<1	<1	112	9.3	1.6
418	1.7	<1	at 522 Hall Fountain R	<1	<1	at 702 Hall Fountain R	<1	<1	108A	1.5	<1
415	1.4	<1	520	<1	<1	at 702 Hall Fountain L	<1	<1	108	<1	<1
406	398	2.7	521	<1	<1	711	1	<1	106A	<1	<1
404	83.3	1.4	513	2.5	<1	710	3.2	<1	105	3.6	<1
402	53.9	1.2	515	1.1	<1	712	1.7	<1	106	2.1	2.1
401	26.3	1.2	515A	3	1.9	713	1.9	<1	107	4.1	<1
403	386	1.3	607	1.3	<1	804	4.5	1.9	115	<1	<1
405	62.3	8	607A	17.3	1.7	809	4.2	1.2	116	<1	<1
407	15	1.2	608	3.3	1.1	809A	6.2	<1	Kitchen	<1	<1
411	5.1	ND	608	8.4	1.1	800 Water Fountain	16.8	9	417	1.8	<1
413	20.2	4.4	605	12	1	Boiler Room	56.9	2.8	415 Sink 2	1.2	<1
412	46.7	ND	605	3.7	<1	810	1	<1	415 Sink 3	1.2	<1
410	20.9	ND	606	2.9	<1	at 800 Hall Fountain	<1	<1	416	<1	<1
414	ND	1	606A	21.6	2.3	300	<1	<1	414 Sink 1	<1	<1
501	ND	ND	at 605 Hall Fountain	<1	2.8	207	<1	<1	414 Sink 2	2.6	1.8
503	3.1	2.8	603	8.1	2.7	205 Sink 1	1.9	<1	522	<1	
503A	1.1	<1	603A	14.6	2.2	205 Sink 2	<1	<1			
505	<1	<1	604	5.2	1.1	205 Sink 3	2.7	2.1			
505A	<1	<1	604A	14.3	2.7	205 Sink 4	<1	<1			
507	<1	<1	601	2.9	1	at 305 Hall Fountain	<1	<1			
507A	1.5	<1	601A	8.8	ND	206	<1	<1			
509	1.6	<1	602	ND	5.7	204 Sink 1	1.2	<1			
509A	1.4	<1	602A	22.8	2.1	204 Sink 2	2.1	<1			
511	1.1	<1	at 601 Hall Fountain	ND	ND	204 Sink 3	1.5	<1			
511A	<1	<1				204 Sink 4	1.5	1.9			

Notes:

- 1 'Draw' is taken immediately device is turned on
- 2 'Flush' is taken after

ND

Equal to NONE DETECTED (No lead content)