

**SUMMER 2022 - RESULTS FOR TESTING OF LEAD IN WATER LEVELS AT 11 APS LOCATIONS**

**(LATEST BATCH IN ROTATING THREE YEAR CYCLE SHOWN IN THIS 'MAINTENANCE' WEB SECTION)**

Collect Date	Location	Param	In Parts/Billion - PPB	
			EPA 200.8	Result
6/9/2022	Arlington Community High School - 1st Floor Bottle filler	Lead	EPA 200.8	ND
6/9/2022	Arlington Community High School - 2nd Floor Bottle filler	Lead	EPA 200.8	ND
6/9/2022	Cardinal Elementary - Cafeteria Bottle Filler	Lead	EPA 200.8	ND
6/9/2022	Cardinal Elementary - Cafeteria Bottle Filler by Rm #136	Lead	EPA 200.8	ND
6/9/2022	Career Center - 1st Floor Bottle Filler	Lead	EPA 200.8	ND
6/9/2022	Career Center - 2nd Floor Bottle Filler by Rm #211	Lead	EPA 200.8	ND
6/9/2022	Discovery Elementary - Bottle Filler at Rm #100	Lead	EPA 200.8	ND
6/9/2022	Discovery Elementary - Kitchen Sink	Lead	EPA 200.8	ND
6/9/2022	Facilities - Bottle filler Main Floor @ Main Door	Lead	EPA 200.8	ND
6/9/2022	Facilities - Bottle filler Lower Floor @ Grounds Shop	Lead	EPA 200.8	0.0004
6/9/2022	Hamm Middle - Bottle filler by Rm #228	Lead	EPA 200.8	ND
6/9/2022	Hamm Middle - Bottle filler by Rm #329	Lead	EPA 200.8	ND
6/9/2022	Hamm Middle - Bottle filler by Rm #112A	Lead	EPA 200.8	ND
6/9/2022	Kenmore Middle - Gym Bottle filler	Lead	EPA 200.8	ND
6/9/2022	Kenmore Middle - Cafeteria Bottle filler	Lead	EPA 200.8	ND
6/9/2022	Kenmore Middle - Bottle filler by Rm #377	Lead	EPA 200.8	ND
6/9/2022	Langston by Rm #115	Lead	EPA 200.8	ND
6/9/2022	Langston - Kitchen Sink	Lead	EPA 200.8	ND
6/9/2022	Wakefield High - Bottle filler outside Cafeteria	Lead	EPA 200.8	ND
6/9/2022	Wakefield High - Bottle filler on 2nd Floor outside B/G Rest Rooms	Lead	EPA 200.8	ND
6/9/2022	Washington Liberty High - By Rm #1008	Lead	EPA 200.8	ND
6/9/2022	Washington Liberty High - By Rm #1600	Lead	EPA 200.8	ND
6/9/2022	Yorktown High - Rm #140F	Lead	EPA 200.8	ND
6/9/2022	Yorktown High - Kitchen Sink	Lead	EPA 200.8	0.0005
<b>NB: All but two are at None Detected (ND) those two are at miniscule traces. Actionable level is 15.00 PPB</b>				
Any questions on these results can be directed to Jim Meikle, Director of Maintenance APS - 703 228 6617				